


TS

5XFY6
L1 L2 L3 N PE
de la BMPT



Pi=16.572kW, kc=0.6, Pc=9.943kW

Legenda:

- separator cu fuzibile trifazic
- disjunctor bipolar cu prot. diferentiala 30mA
- disjunctor bipolar normal

Proiectant General :S.C. BIROU DE PROIECTARE ABSTRUKT SRL

Proiectant de Specialitate Instalatii Electrice : PFA BALINT SZILARD F14/285/02.06.2008 CUI: 23985890				Beneficiar: MUNICIPIUL TARGU SECUIESC	Nr.Proiect gen ----- Nr.Proiect spec 1614/2016 Faza: P.T.
				Amplasament: str. Libertatii, nr. 19, Tg. Secuiesc, jud. Covasna	
Specificatie	Nume	Semnatura	Scara: %	Titlu proiect: SCHIMBARE DESTINATIE PUNCT TERMIC IN CENTRU DE RECREERE	
Sef proiect	ing. Fekete Zoltan			Titlu plansa: SCHEMA MONOFILARA Instalatii electrice de distributie si utilizari generale 0,4kV	
Proiectat	ing. Balint Szilard		Data: IV.2016		Plansa nr.: E-01
Desenat	ing. Balint Szilard				